

INDOOR AIR QUALITY TRANSMITTERS SIRO SERIES

Multifunctional indoor air quality transmitters for building automation systems

Siro is an indoor air quality transmitter with a modern design. The transmitter is available with several optional air quality sensors. The modular device can be equipped with CO₂ concentration and VOC (Volatile Organic Compounds) measurements or alternatively PM (Particulate Matter) measurement and in addition temperature and humidity measurements. It offers easy installation and adjustment, several different model options and various output signals that are configurable separately for each measurement parameter. The Siro series devices are available with user interface that includes LCD display and buttons making the configuration of the device quick and easy. An external configuration tool is available for devices without user interface. Siro utilizes the industry standard NDIR measurement principle with self-calibrating ABC logic™ for CO₂ measurement.

Siro series devices include:

- Several options for indoor air quality measurements (CO₂, VOC, PM, rH, T).
- Field configurable outputs for selected measurements.
- Proportional output options including voltage (0–10 V, 0–5 V, 2–10 V) and optional current (4–20 mA).
- Offset feature enabling field calibration for each measurement parameter (CO₂, VOC, PM, rH, T).
- Optional LCD-display and buttons.



APPLICATIONS

Siro series devices are commonly used to monitor and control:

- indoor air quality in offices, public spaces, meeting rooms and classrooms
- CO₂ and VOC concentration to regulate demand-controlled ventilation and to keep the indoor air quality in a good level
- PM concentration to measure the size and amount of particulates in the indoor air for example to assess the performance of air filters
- temperature and humidity in HVAC/R environment

MODEL SUMMARY

Model	Product code	Model	Product code	Model	Product code	Model	Product code
Siro-CO2	304.001.001	Siro-CO2-rH-T-D	304.001.011	Siro-PM	304.003.001	Siro-PM-T-D	304.003.011
Siro-CO2-A	304.001.002	Siro-CO2-rH-T-A-D	304.001.012	Siro-PM-A	304.003.002	Siro-PM-T-A-D	304.003.012
Siro-CO2-D	304.001.003	Siro-CO2-T	304.001.013	Siro-PM-D	304.003.003	Siro-rH-T	304.004.001
Siro-CO2-A-D	304.001.004	Siro-CO2-T-A	304.001.014	Siro-PM-A-D	304.003.004	Siro-rH-T-A	304.004.002
Siro-CO2-VOC-rH-T	304.001.005	Siro-CO2-T-D	304.001.015	Siro-PM-rH-T	304.003.005	Siro-rH-T-D	304.004.003
Siro-CO2-VOC-rH-T-A	304.001.006	Siro-CO2-T-A-D	304.001.016	Siro-PM-rH-T-A	304.003.006	Siro-rH-T-A-D	304.004.004
Siro-CO2-VOC-rH-T-D	304.001.007	Siro-VOC-rH-T	304.002.001	Siro-PM-rH-T-D	304.003.007	Siro-T	304.004.005
Siro-CO2-VOC-rH-T-A-D	304.001.008	Siro-VOC-rH-T-A	304.002.002	Siro-PM-rH-T-A-D	304.003.008	Siro-T-A	304.004.006
Siro-CO2-rH-T	304.001.009	Siro-VOC-rH-T-D	304.002.003	Siro-PM-T	304.003.009	Siro-T-D	304.004.007
Siro-CO2-rH-T-A	304.001.010	Siro-VOC-rH-T-A-D	304.002.004	Siro-PM-T-A	304.003.010	Siro-T-A-D	304.004.008

CO₂ = Carbon dioxide sensor, VOC = Volatile Organic Compounds sensor, PM = Particulate Matter sensor, rH = Humidity sensor, T = Temperature sensor, A = mA output, D = Display

PRC Technologies Corp., Ltd. ลาดพร้าว 101 กรุงเทพฯ 10240

www.prctech-th.com

โทรศัพท์ : 02 530 1714, 02 932 1711 มือถือ : 086 360 8600

อีเมล : contact@prctech.net LINE ID1: [prctech-info](https://www.prctech-th.com), LINE ID2 : [@prctec](https://www.prctech-th.com)

INDOOR AIR QUALITY TRANSMITTERS

SIRO SERIES

SPECIFICATIONS

Performance

Measurement ranges:

CO₂: 0–2000 ppm / 400–2000 ppm
(selectable via jumper)

VOC: CO₂eq: 400–2000 ppm
TVOC ppm: 0–30.0 ppm
TVOC µg/m³: 0–10000 µg/m³
IAQ index: 1–5 (UBA rating)

PM1/PM2.5/PM10: 0–50 µg/m³ / 0–500 µg/m³
(selectable via jumper)
IAQ index: 1–5 (WHO rating)

Temperature: 0...50 °C
Relative humidity: 0–100 %rH

Accuracy:

CO₂: ±43 ppm + 3 % of reading (typical),
additional ±60 ppm for first weeks

VOC*: 15 % of reading (typical)
*VOC sensor is tuned for typical IAQ Mix of 22 VOCs as
defined by Mølhave et al. (1997)

PM:
0...100 µg/m³:
PM2.5: ±15 µg/m³ (at 25 °C ±5 °C)
PM1/PM10*: ±25 µg/m³ (at 25 °C ±5 °C)

100...1000 µg/m³:
PM2.5: ±15 % (at 25 °C ±5 °C)
PM1/PM10*: ±25 % (at 25 °C ±5 °C)
*PM1 and PM10 values are calculated from PM2.5
measurement reading with the default particle distribution.

Temperature: ±0.5 °C (typical at 20 °C)
Relative humidity: ±2.4 %rH (typical at 20 °C, 30 % rH)

Technical Specifications

Media compatibility:

Dry air or non-aggressive gases

Measuring units:

CO₂: ppm
VOC: CO₂eq: ppm
TVOC: ppm, µg/m³
PM1/PM2.5/PM10: µg/m³
PM: PM1/PM2.5/PM10: µg/m³
Temperature: °C/°F
Relative humidity: %rH

Measuring element:

CO₂: Non-dispersive infrared (NDIR)
VOC: Complementary Metal Oxide Semiconductor (CMOS)
PM: Laser-based light scattering particle sensing
Temperature: Integrated to CMOS
Relative humidity: Thermoset polymer capacitive sensing element

Calibration:

Automatic self-calibration ABC Logic™ for CO₂
measurement

Environment:

Operating temperature: 0...50 °C
Storage temperature: -20...70 °C
Humidity: 0 to 95 %rH, non condensing

Physical

Dimensions:

Case: 95 x 103 x 30 mm
(width x height x depth)

Weight:

130 g

Mounting:

2 screw holes slotted, distance c/c 60 mm

Materials:

Case: ABS

Protection standard:

IP20

Display (optional)

Monochrome LCD, 38 x 23 mm

Electrical connections:

8-pin spring loaded terminal block
0.2...1.5 mm² (16-24 AWG)

Electrical

Input:

24 VAC or VDC, ±10 %
Power consumption: 2 W max + 25 mW for each
voltage output or 50 mW for each current output

Outputs:

4 outputs, have to select voltage or current

Voltage outputs:

0–10 V
2–10 V / 0–5 V (optional, display or configuration
tool required)

Current output:

4–20 mA (optional)

Output signal limits:

Voltage outputs: R > 1 kΩ
Current output: R > 20 Ω, R < 500 Ω

Conformance

Meets requirements for:

CE:	UKCA:
EMC: 2014/30/EU	S.I. 2016/1091
RoHS: 2011/65/EU	S.I. 2012/3032
WEEE: 2012/19/EU	S.I. 2013/3113

COMPANY WITH
MANAGEMENT SYSTEM
CERTIFIED BY DNV
ISO 9001 • ISO 14001



HOW TO GENERATE A MODEL?

Example:	Product series					
	Siro	Indoor air quality transmitter				
Siro-CO2-T-D		CO ₂ sensor				
	-CO2	With CO ₂ sensor (option not available with PM sensor)				
		Without CO ₂ sensor				
		VOC sensor				
	-VOC	With VOC sensor (option not available with PM sensor)				
		Without VOC sensor				
		PM sensor				
	-PM	With PM sensor (option not available with CO ₂ and VOC sensors)				
		Without PM sensor				
		Relative humidity sensor				
	-rH	With relative humidity sensor				
		Without relative humidity sensor (option not available with VOC sensor)				
		Temperature sensor				
	-T	With temperature sensor				
		Without temperature sensor (option not available with VOC or rH sensor)				
		Output				
		Voltage output				
	-A	Voltage and current output				
		Display				
		-D With display				
		Without display				
Model	Siro	-CO2			-T	-D